

PRODUCT DATA SHEET

Published: 2026-09-18

Hose set

G 1 1/2", 20 m

Part Number: A0000006

Features

- Includes 2 hoses and 4 sets of fittings



Technical Features

Operating temperature range

30 ... 80 °C

Connection 1 thread (outer)

1 1/2"

Connection 2 thread (outside)

1 1/2"

Inner diameters

38 mm

Outer diameter

52 mm

Insulation thickness

9 mm

Material

SBR

Reserve technical changes

LAUDA DR. R. WOBSEY GMBH & CO. KG
Laudaplatz 1 • 97922 Lauda-Königshofen • DE

T + 49 (0) 9343 503-0
info@lauda.de • www.lauda.de
WEEE-Reg-Nr.: DE 66 42 40 57

Kommanditgesellschaft: Sitz Lauda-Königshofen
Registergericht Mannheim • HRA 560069

Persönlich haftende Gesellschafterin:
LAUDA DR. R. WOBSEY Verwaltungs-GmbH
Sitz Lauda-Königshofen
Registergericht Mannheim • HRB 560226

Geschäftsführer:
Dr. Gunther Wobser (Vors.), Dr. Mario Englert,
Dr. Marc Stricker
Beirat: Dr. Gerhard Wobser

PRODUCT DATA SHEET

Published: 2026-09-18

Hose set

G 1 1/2", 20 m

Part Number: A0000006

CHILLER SIDE

WATER INLET

1 X HOSE CARRIER
FLEXIBLE PIPE
1 X CLAMP
THERMAL INSULATION
INSULATION TAPE



WATER OUTLET

1 X HOSE CARRIER
FLEXIBLE PIPE
1 X CLAMP
THERMAL INSULATION
INSULATION TAPE



APPLICATION SIDE

WATER INLET

1 X HOSE CARRIER
1 X CLAMP
1 X FEMALE- FEMALE

WATER OUTLET

1 X HOSE CARRIER
1 X CLAMP
1 X FEMALE- FEMALE

Reserve technical changes

LAUDA DR. R. WOBSEY GMBH & CO. KG
Laudaplatz 1 • 97922 Lauda-Königshofen • DE

T + 49 (0) 9343 503-0
info@lauda.de • www.lauda.de
WEEE-Reg-Nr.: DE 66 42 40 57

Kommanditgesellschaft: Sitz Lauda-Königshofen
Registergericht Mannheim • HRA 560069

Persönlich haftende Gesellschafterin:
LAUDA DR. R. WOBSEY Verwaltungs-GmbH
Sitz Lauda-Königshofen
Registergericht Mannheim • HRB 560226

Geschäftsführer:
Dr. Gunther Wobser (Vors.), Dr. Mario Englert,
Dr. Marc Stricker
Beirat: Dr. Gerhard Wobser