

## PRODUCT DATA SHEET

Standing: 2021-07-15

### LAUDA Ultracool UC 65

Circulation chiller 400 V; 3/PE; 50 Hz

Part Number: L002949

#### Features

- Highly efficient industrial chiller in closed cabinet
- LCD remote control with 5 m cable
- Operation possible via web server
- Electronic 2-point temperature control
- Protection level IP 54 (for outdoor installation)
- Industrial block pump with high pressure and high flow rate
- Integrated water filter
- Integrated Ethernet interface
- Inlet and outlet water connections in stainless steel
- Operates with non flammable liquids (water, water/glycol)
- Meeting the energy efficiency requirements of the EcoDesign directive 2009/125/EC
- Condenser cooling Air

#### Options included

- Reinforced pump (5bar)



Working temperature min.  
-10 °C



Working temperature max.  
35 °C



Reserve technical changes

LAUDA DR. R. WOBSEY GMBH & CO. KG  
Pfarrstraße 41/43 • 97922 Lauda-Königshofen  
Postfach 1251 • 97912 Lauda-Königshofen • DE

T + 49 (0) 9343 503-0 • F + 49 (0) 9343 503-222  
info@lauda.de • www.lauda.de  
WEEE-Reg.-Nr.: DE 66 42 40 57

Kommanditgesellschaft: Sitz Lauda-Königshofen  
Registergericht Mannheim • HRA 560069

Persönlich haftende Gesellschafterin:  
LAUDA DR. R. WOBSEY Verwaltungs-GmbH  
Sitz Lauda-Königshofen  
Registergericht Mannheim • HRB 560226

Geschäftsführer:  
Dr. Gunther Wobser (Vors.), Dr. Mario Englert,  
Dr. Marc Stricker  
Beirat: Dr. Gerhard Wobser

## PRODUCT DATA SHEET

Standing: 2021-07-15

LAUDA Ultracool UC 65

Circulation chiller 400 V; 3/PE; 50 Hz

Part Number: L002949

### Technical Features

Working temperature range	-10 ... 35 °C
Ambient temperature range	-15 ... 50 °C
Temperature stability	0.5 ± K
Filling volume max.	210 L
Pump Pressure max.	6.9 bar
Pump flow rate pressure max.	367 L/min
Pump flow rate nominal	196 L/min
In / Outlet connection thread (inside)	Rp 1 1/2
Overall dimensions (WxDxH)	1040 x 1435 x 1890 mm
Noise level	69.5 dB(A)
Refrigerant stage 1	R-410A (GWP 2088); 6.000 kg; 12.5 t CO <sub>2</sub> -eq
SEPR	5.16
Power supply	400 V; 3/PE; 50 Hz

Reserve technical changes

LAUDA DR. R. WOBSEY GMBH & CO. KG  
Pfarrstraße 41/43 • 97922 Lauda-Königshofen  
Postfach 1251 • 97912 Lauda-Königshofen • DE

T + 49 (0) 9343 503-0 • F + 49 (0) 9343 503-222  
info@lauda.de • www.lauda.de  
WEEE-Reg-Nr.: DE 66 42 40 57

Kommanditgesellschaft: Sitz Lauda-Königshofen  
Registergericht Mannheim • HRA 560069

Persönlich haftende Gesellschafterin:  
LAUDA DR. R. WOBSEY Verwaltungs-GmbH  
Sitz Lauda-Königshofen  
Registergericht Mannheim • HRB 560226

Geschäftsführer:  
Dr. Gunther Wobser (Vors.), Dr. Mario Englert,  
Dr. Marc Stricker  
Beirat: Dr. Gerhard Wobser

## PRODUCT DATA SHEET


Standing: 2021-07-15

LAUDA Ultracool UC 65

Circulation chiller 400 V; 3/PE; 50 Hz

Part Number: L002949

Temperature	Cooling Capacity 50 Hz
25 °C	87.5 kW
20 °C	85.2 kW
15 °C	77.4 kW
10 °C	66.9 kW
5 °C	57.3 kW
0 °C	47.8 kW
-5 °C	40.1 kW
-10 °C	33.3 kW



Reserve technical changes

LAUDA DR. R. WOBSEY GMBH & CO. KG  
Pfarrstraße 41/43 · 97922 Lauda-Königshofen  
Postfach 1251 · 97912 Lauda-Königshofen · DE

T + 49 (0) 9343 503-0 · F + 49 (0) 9343 503-222  
info@lauda.de · www.lauda.de  
WEEE-Reg-Nr.: DE 66 42 40 57

Kommanditgesellschaft: Sitz Lauda-Königshofen  
Registergericht Mannheim · HRA 560069

Persönlich haftende Gesellschafterin:  
LAUDA DR. R. WOBSEY Verwaltungs-GmbH  
Sitz Lauda-Königshofen  
Registergericht Mannheim · HRB 560226

Geschäftsführer:  
Dr. Gunther Wobser (Vors.), Dr. Mario Englert,  
Dr. Marc Stricker  
Beirat: Dr. Gerhard Wobser