

PRODUCT DATA SHEET

Ultracool UC-1350 SP

Within the Ultracool Maxi range, there are four chillers with cooling outputs from 34.1 up to 64.4 kW which work with one single refrigeration circuit. The five models from 87.9 up to 265 kW of cooling capacities work with two independent refrigeration circuits to provide a backup security. All Maxi models are equipped with scroll compressors, work with R 407C as refrigerant and are suitable for outdoor installation. The internal pipes for the water circuit are made of PP-R (polypropylene random copolymer) and are thermowelded. Besides the main advantage that these connections are absolutely leak free, PP-R is corrosion and frost proof, allow for smaller pressure drops and are long lasting. The models UC-0300 to UC-0650 are also available as UC laser models with pre-configured options included.



Working temperature min.

-5°C



Working temperature max.

25 °C.

Technical Attributes	Ultracool UC-1350 SP
Working temperature min.	-5 °C
Working temperature max.	25 °C
Ambient temperature min.	-15 °C
Ambient temperature max.	45 °C
Temperature stability	2 ±K
Cooling output at 25°C water outlet temperature	182.1 kW
Cooling output at 20°C water outlet temperature	182.1 kW
Cooling output at 15°C water outlet temperature	163.7 kW
Cooling output at 10°C water outlet temperature	139.2 kW
Cooling output at 5°C water outlet temperature	113.7 kW
Cooling output at 0°C water outlet temperature	90 kW
Cooling output at -5°C water outlet temperature	69.8 kW
Number of refrigeration circuits	2
Application	external
Pump pressure max.	5 bar

LAUDA DR. R. WOBSER GMBH & CO. KG Pfarrstraße 41/43 • 97922 Lauda-Königshofen Postfach 1251 • 97912 Lauda-Königshofen • DE

T +49 (0) 9343 503-0 · F +49 (0) 9343 503-222 info@lauda.de · www.lauda.de WEEE-Reg-Nr.: DE 66 42 40 57 Kommanditgesellschaft: Sitz Lauda-Königshofen Registergericht Mannheim • HRA 560069

Personlich hattende Gesellschatterin: LAUDA DR. R. WOBSER Verwaltungs-GmbH Sitz Lauda-Königshofen Registergericht Mannheim • HRB 560226 Geschäftsführer: Dr. Gunther Wobser (Vors.), Dr. Mario Englert Dr. Marc Stricker Beirat: Dr. Gerhard Wobser



PRODUCT DATA SHEET

Ultracool UC-1350 SP

Technical Attributes	Ultracool UC-1350 SP
Pump pressure nominal	4.3 bar
Pump flow max. (pressure)	750 L/min
Pump flow nominal	392 L/min
Pump connection thread	Rp 2 1/2"
Volume water reservoir	500 L
Dimensions (WxDxH) in mm	1660x3400x2090
Max. fuse	150 A

LAUDA DR. R. WOBSER GMBH & CO. KG Pfarrstraße 41/43 • 97922 Lauda-Königshofen Postfach 1251 • 97912 Lauda-Königshofen • DE

T +49 (0) 9343 503-0 · F +49 (0) 9343 503-222 info@lauda.de · www.lauda.de WEEE-Reg-Nr.: DE 66 42 40 57 Kommanditgesellschaft: Sitz Lauda-Königshofen Registergericht Mannheim • HRA 560069

Persönlich haftende Gesellschafterin: LAUDA DR. R. WOBSER Verwaltungs-GmbH Sitz Lauda-Königshofen Registergericht Mannheim • HRB 560226 Geschäftsführer: Dr. Gunther Wobser (Vors.), Dr. Mario Englert Dr. Marc Stricker Beirat: Dr. Gerhard Wobser